

Date : 09.03.2021

TUV Rheinland Korea Ltd.
2F, Young City, N-Tower, 25
Mullae-ro 28-gil, Yeongdeungpo-gu
Seoul 07298
Republic of Korea
Attn: Seung-Wook Lee

Re. : TU TUV Rheinland US Mark

Type of Equipment : Secondary Pack, LiNiMnCoO₂, as page 0001
Model Designation : See Certificate
Certificate No. : TU 50489155 0002
File No. : 60407004 002
Engineer/Contact : Seung-Wook Lee
Standard(s) : ANSI/CAN/UL 1973:2018

Dear Mr. Seung-Wook Lee,

Please find enclosed certification documents as specified above.

Please forward these originals to the certificate holder.

If you contact our office, please quote our reference above.

We thank you for your cooperation.

If we can be of any further assistance to you,
please do not hesitate to contact us.

Sincerely yours,
Certification Body



Vilmos Sztaroveczki

Enclosure

Date : 09.03.2021

LG Energy Solution, LTD.
188, Munji-ro, Yuseong-gu,
Daejeon,
Republic of Korea

Attn:

Re. : TU TUV Rheinland US Mark

Type of Equipment : Secondary Pack, LiNiMnCoO₂, as page 0001
Model Designation : See Certificate
Certificate No. : TU 50489155 0002
File No. : 60407004 002
Engineer/Contact : Seung-Wook Lee
Standard(s) : ANSI/CAN/UL 1973:2018

Dear Madame or Sir,

The above specified technical equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

We appreciate your support and would like to offer our assistance in the approval of your future products through our extensive range of technical services. Please feel free to contact us whatever your requirements may be.

If we can be of any further assistance to you, please do not hesitate to contact us.

Sincerely yours,
Certification Body



Vilmos Sztaroveczki

Enclosure

Certificate



Certificate no.

TU 50489155 02

License Holder:

LG Energy Solution, LTD.
188, Munji-ro, Yuseong-gu,
Daejeon,
Republic of Korea

Manufacturing Plant:

PEOPLEWORKS
225, Suchul-daero,
Gumi-si, Gyeongsangbuk-do 39270
Republic of Korea

Test report no.: USA-SWL 60407004 002

Client Reference: 40824897 / 156136639

Tested to: ANSI/CAN/UL 1973:2018

Certified Product: Secondary Pack, LiNiMnCoO₂, as page 0001

License Fee - Units

Addition

Type Designation: RESU 10H Prime
Pack Configuration: [42S_1P Cells]

1

Nominal Voltage: 154.14 V
Nominal Charging Voltage: 174.3 V
Watt-hour Rating: 9.87 kWh

1

Appendix: 1.1

Licensed Test mark:



Date of Issue
(day/mo/yr)

09/03/2021